

**ADDENDUM NO. 1**  
**EARL TILE DRAIN**  
**SAGINAW COUNTY, MICHIGAN**

**TO: ALL PROSPECTIVE BIDDERS ON THE SUBJECT PROJECT**

**RE: CHANGES TO BIDDING DOCUMENTS**

*Acknowledge Receipt of this Addendum on Page P-1  
of the Bidform (Proposal) where indicated.*

The following is a list of clarifications to the bidding documents:

1. Addendum No. 1 has been posted to the Saginaw County Public Work Commissioner's website (<http://www.saginawcounty.com/PublicWorks/Current-Projects.aspx>) on Monday, October 10, 2016.
2. The existing main line tile is to be removed as part of the installation of the new 36-inch storm sewer as shown on the details on sheet 6 of the plans. All costs are to be included in the unit bid price per linear foot for installing the new tile as stated in the specifications (2722-1, 1.3, A.).
3. All active service connections, sump pump connections, field tile connections, etc. that are connected to the existing storm sewer tile are to be reconnected to the proposed storm sewer at proposed drainage structures when nearby, or directly to the proposed sewer with an Inserta-tee connection when no proposed drainage structures are nearby. All costs included in Bid Item No. 10 – Lateral Tile Connections, as stated in the specifications.
4. There is no engineer's estimate available to bidders.


An unsigned acknowledgement or lack of acknowledgement shall be cause to have the bid rejected. Acknowledgment of the Addendum No. 1 by the bidder shall indicate full understanding and acceptance of this addendum in its entirety.

Please sign the Acknowledgment below and attach this Addendum No. 1 to the front of your bidding document. Acknowledge the same in the Bid Form (Proposal).

This Acknowledgement Form must be included with the sealed bid.

Prepared by:

SPICER GROUP, INC.

  
Nicholas D. Czerwinski, P.E.  
Project Manager

**ACKNOWLEDGMENT**

BIDDER: \_\_\_\_\_

BY: \_\_\_\_\_

DATE: \_\_\_\_\_