

ADDENDUM NO. 2

NEW TAMARACK DRAIN SAGINAW COUNTY, MICHIGAN

TO: ALL PROSPECTIVE BIDDERS ON THE SUBJECT PROJECT

RE: CHANGES TO BIDDING DOCUMENTS

*Acknowledge Receipt of this Addendum on Page C-410-1
of the Bidform (Proposal) where indicated.*

The following is a list of changes to the bidding documents:

1. Addendum No. 2 has been emailed to you on Friday, April 26th, 2024.
2. The following clarification is being made in response to questions received from the plan holders:
 - All corrugated metal pipe shall be Type II Aluminized.
 - Surface outlet tubes
 - i. Surface outlet tubes are to be 35' as stated on the bid form. The length is incorrectly shown as 40' on the plans.
 - ii. No anti-seep collar will be required for this project.
 - Temporary Crossing - Bid Item # 61
 - i. Material type and length are to be determined by the contractor to safely cross the drain and complete the required work on the other side. The culvert must be a minimum 60" diameter. A used culvert of appropriate size and length that is in good condition would be acceptable.
 - Bid Item #55 to #60
 - i. Culverts are to be 2-2/3" x 1/2". The bid form incorrectly states 2-3/4" x 1/2". A new bid form will not be issued.

Note all clarifications and changes contained within this Addendum and/or the Pre-Bid meeting minutes supersede any data that may be contained in the plans and specifications regarding the same matter.

An unsigned acknowledgement or lack of acknowledgement shall be cause to have the bid rejected. Acknowledgment of the Addendum No. 2 by the bidder shall indicate full understanding and acceptance of this addendum in its entirety.

Please sign the Acknowledgment below and attach this Addendum No. 2 to the front of your bidding document. Acknowledge the same in the Bid Form (Proposal).

Included with the sealed bid should be:

- A. The Bid Form with Addendum No. 2 acknowledged
- B. A copy of this Addendum with the Acknowledgement Form completed

Prepared by:

SPICER GROUP, INC.



Luke D. O'Brien, P.E.
Project Manager

ACKNOWLEDGMENT

BIDDER: _____

BY: _____

DATE: _____